



Certificate number: 2405718 (1)

Issued 21/05/2024

Expires 21/05/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Building Products Distributors Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Building Products Distributors Ltd
Unit 21
Avondale Business Park
Ballyclare
BT39 9AU
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2405718

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of waste water heat recovery units with copper bodies and twin wall separation. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) Showersave QB1-21XE Showersave QB1-10XE</p>
<p>SIZE: ½" BSP(F).</p>
<p>SCOPE: Manufacturer recommended maximum working pressure: Primary side 1 bar, Secondary side 8 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C.</p>
<p>MARKING Model no, QR code, QR code on data label. Building Products Distribution Ltd, address, model no and other technical information on body.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES N/A.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes